


A11100 995661

NBS
PUBLICATIONS



NBSIR 81-2444

Smoke Movement Through A Suspended Ceiling System

U.S. DEPARTMENT OF COMMERCE
National Bureau of Standards
National Engineering Laboratory
Center for Fire Research
Washington, DC 20234

Issued:
February 1982

Final Report

Funded in part by:

Veterans Administration
Office of Construction Research
Washington, DC 20420

Department of Health and Human Services
Washington, DC 20201

QC

100

.U56

81-2444

1982

c. 2

NBSIR 81-2444

NATIONAL BUREAU
OF STANDARDS
LIBRARY

MAY 14 1982

SMOKE MOVEMENT THROUGH A SUSPENDED CEILING SYSTEM

John H. Klote

U.S. DEPARTMENT OF COMMERCE
National Bureau of Standards
National Engineering Laboratory
Center for Fire Research
Washington, DC 20234

Issued:
February 1982

Final Report

Funded in part by:
Veterans Administration
Office of Construction Research
Washington, DC 20420

Department of Health and Human Services
Washington, DC 20201



U.S. DEPARTMENT OF COMMERCE, Malcolm Baldrige, *Secretary*
NATIONAL BUREAU OF STANDARDS, Ernest Ambler, *Director*

TABLE OF CONTENTS

	Page
LIST OF FIGURES	v
LIST OF TABLES ;	vii
Abstract	1
1. INTRODUCTION	2
2. TEST FACILITY	3
3. EXPERIMENTAL DETAILS	5
3.1 Instrumentation	5
3.1.1 Temperature	5
3.1.2 Smoke Obscuration	5
3.1.3 Carbon Monoxide	5
3.1.4 Velocity	6
3.2 Test Program	6
3.3 Test Procedures	6
3.3.1 Smoke Candle Test	6
3.3.2 Smoldering Tests	7
3.3.3 Low Energy Tests	7
3.3.4 High Energy Tests	8
3.4 Mattresses and Bedding	8
3.4.1 Low Energy Tests	8
3.4.2 High Energy Tests	9
4. HAZARD ANALYSIS	9
4.1 Smoke Obscuration	10
4.2 Carbon Monoxide	10
5. TEST RESULTS AND DISCUSSION	11
5.1 Smoke Candle Test	11
5.2 Smoldering Tests	12
5.2.1 Tests 1 and 2	12
5.2.2 Test 3	13
5.3 Low Energy Tests	14
5.3.1 Tests 4 and 5	14
5.3.2 Test 6	15
5.3.3 Test 7	16
5.3.4 Test 8	16
5.3.5 Test 9	17
5.3.6 Test 10	18

TABLE OF CONTENTS (cont'd)

	Page
5.4 High Energy Tests	19
5.4.1 Tests 11 and 12	19
5.4.2 Smoke Leakage into Room 2	20
5.4.3 Smoke Movement through the Ceiling	21
5.5 Comparison of Test Types	22
5.5.1 Smoke Movement	22
5.5.2 Hazardous Conditions	22
5.5.3 Smoke Detection	23
5.6 Interstitial Space Exhaust	24
5.7 Patient Room Exhaust	26
5.8 Smoke Movement Paths	27
 6. SUMMARY AND CONCLUSIONS	 28
7. ACKNOWLEDGEMENTS	30
8. REFERENCES	31

LIST OF FIGURES

	Page
Figure 1. Floor plan of test facility	33
Figure 2. Section of test facility	34
Figure 3. Ceiling plan of test facility	35
Figure 4. Ventilation system for test facility	36
Figure 5. Instrumentation plan for test facility	37
Figure 6. Instrumentation plan for interstitial space	38
Figure 7. Instrumentation in burn room doorway	39
Figure 8. Instrumentation in burn room	40
Figure 9. Instrumentation in room 1	41
Figure 10. Floor plan for test facility showing status of doors and windows during the tests	42
Figure 11. Smoke obscuration for the smoke candle test	43
Figure 12. Smoke obscuration in the burn room and the interstitial space for tests 1 and 2	44
Figure 13. Smoke obscuration in the burn room and the interstitial space for tests 2 and 3	45
Figure 14. Upper gas temperatures for tests 4 through 7	46
Figure 15. Upper gas temperatures for tests 8 through 10	47
Figure 16. Smoke obscuration for tests 4 and 5	48
Figure 17. Smoke obscuration for test 5	49
Figure 18. Carbon monoxide concentrations for test 5	50
Figure 19. Smoke obscuration for test 6	51
Figure 20. Smoke obscuration for test 7	52
Figure 21. Carbon monoxide concentrations for tests 6 and 7	53
Figure 22. Smoke obscuration for test 8	54

LIST OF FIGURES (cont'd)

	Page
Figure 23. Smoke obscuration for test 9	55
Figure 24. Smoke obscuration for test 10	56
Figure 25. Temperatures for test 11	57
Figure 26. Temperatures for test 12	58
Figure 27. Smoke obscuration for tests 11 and 12	59
Figure 28. Carbon monoxide concentrations for tests 11 and 12 . .	60
Figure 29. Pressure difference across burn room ceiling for tests 10, 11 and 12	61
Figure 30. Smoke obscuration for the smoke candle test and test 1	62

LIST OF TABLES

	Page
Table 1. Fan Schedule	63
Table 2. List of Instrumentation	64
Table 3. Test Schedule	66
Table 4. Ignition Source	67
Table 5. Technical Data for Mattress and Bedding for Tests 4 - 10	68
Table 6. Technical Data for Mattress and Bedding for Tests 11 and 12	69
Table 7. Times to Hazard Level Due to CO Concentrations	70
Table 8. Smoke Detector Activation Times	71

SMOKE MOVEMENT THROUGH A SUSPENDED CEILING SYSTEM

John H. Klote

Abstract

A series of full-scale tests were conducted to evaluate smoke movement through a suspended ceiling and into an interstitial space of a hospital type facility. A test facility specifically constructed for this project is described. The test series consisted of one smoke candle test and 12 fire tests including both smoldering and flaming fires. Smoke movement through the suspended ceiling system was evaluated in terms of the total smoke movement through the test facility. The effects of ventilation and smoke exhaust on smoke concentration in the test facility were investigated. It was concluded that the use of the interstitial space exhaust as described in this paper will effectively prevent hazard conditions due to smoke downflow through suspended ceilings. It was also concluded that smoldering fires of the type examined in this test series are not a significant problem in hospitals.

Key words: Ceiling systems; hazard analysis; hospitals; interstitial space; mattresses; smoke control; smoke exhaust; smoke movement; ventilation systems.

1. INTRODUCTION

Smoke¹ is commonly recognized as a major killer in building fires. One of the reasons for this is that smoke flows through numerous leakage paths to locations remote from the fire, resulting in a hazard to human life. These leakage paths can be open doors, cracks around closed doors, stairwells, elevator shafts, construction cracks in walls and floors, and even cracks or openings in a suspended acoustical ceiling.

Extensive use of suspended acoustical ceilings has resulted in questions within the Veterans Administration (VA) and among the fire protection community regarding the potential of danger resulting from smoke leakage through the ceiling. This is especially true for cases where there are large areas above the suspended ceiling, such that smoke could travel through these paths to locations remote from the fire. Such smoke movement could involve smoke movement up through the ceiling, horizontal flow in the space above the ceiling, and then downward flow into an occupied space.

This paper reports the results of a test series conducted to evaluate smoke movement through a suspended ceiling system. Particular emphasis in this study was directed toward examining this problem under a construction arrangement typical of a hospital. A test facility was constructed which consisted of four patient rooms and a section of corridor. Above these spaces there was an open space referred to as the interstitial space. The interstitial space was separated from the lower spaces by a suspended ceiling system. In hospitals the interstitial space is typically used for mechanical and electrical equipment, ductwork, piping, and conduit.

¹Smoke is defined for this paper to consist of all airborne products of combustion including both particles and gases.

In this test series the extent of smoke penetration through the ceiling was evaluated from (1) smoke candles, (2) smoldering fires, (3) low energy flaming fires, and (4) high energy flaming fires. Smoke concentrations were determined by measuring smoke obscuration and CO concentration. Smoke concentrations were recorded in a number of locations throughout the test facility in order to evaluate smoke movement through the ceiling system in light of smoke movement throughout the rest of the test facility. The effects of the ventilation, occupancy space exhaust, and interstitial space smoke exhaust on smoke concentration in the test facility were also investigated. In addition, a hazard analysis, limited to smoke obscuration and CO concentration, is included.

2. TEST FACILITY

The test facility was built inside another structure to minimize the effect of the wind. This facility has four patient rooms and a section of corridor as shown in figure 1. The burn room has one door to the corridor and another smaller door to the space outside the test facility. This smaller door was included to provide a convenient exit. This door was closed throughout all the tests except for the first 5 to 10 seconds of each test when the person who ignited the test fire was exiting. Reference in this report to the "burn room door" will mean the door between the burn room and the corridor.

The doors throughout the test facility had polymer seals on both sides and the top. These seals were a commercial product which was specifically made for use on metal door frames. The sealing mechanism was a thin polymer leaf against which the door closed. Small leakage paths existed at the corners where these seals met. The doors were undercut 23 mm (7/8 in). No attempt was made to seal these cracks at the bottom of the doors from the four rooms into the corridor. However, bottom sweeps were installed on the two doors to the outside of the test facility.

Figure 2 shows a section through the test facility. The walls of the facility consist of 16 mm (5/8 in) type X gypsum board on steel studs. All of the gypsum board joints were taped and spackled. The perimeter walls of the test facility have gypsum board on the interior side only. The interior walls are 2.44 m (8 ft) high and have gypsum board on both sides. The suspended ceilings are separately hung in each room.

The ceiling was constructed of 0.61 x 1.22 m (24 x 48 in) acoustical tiles supported by a steel grid system. The ceiling plan is shown in figure 3. The construction of the ceiling was (see figure 2) in accordance with the ceiling portion of UL listing A202 [1]², floor ceiling assembly, with the exception that ceiling hold down clips were left off one ceiling tile in each room and one tile in the corridor. These unclipped tiles were used as access panels. In addition, an open cell polymer seal was installed between the ceiling wall molding and the wall, as is common practice in Veterans Administration hospitals. The ceiling tiles weighed 49.6 N/m² (1.00 lb/ft²).

The ventilation system for the test facility is shown in figure 4. This system consists of supply and exhaust for the four patient rooms as well as ventilation for the interstitial space. Table 1 is a schedule of the ventilation fans. The system was designed and balanced to provide six air changes per hour in the patient rooms. Four radial fans were installed for ventilation of the interstitial space. These fans are capable of being repositioned in the ductwork so that they can be used for either supply or exhaust of the interstitial space. Each radial fan has a damper for adjusting air flow. During this test series the only radial fan used was fan 5 in the exhaust mode. All of the outside air dampers were motorized.

²Numbers in brackets refer to references listed at the end of this paper.

3. EXPERIMENTAL DETAILS

3.1 Instrumentation

The instruments used in this test series are shown in figures 5 thru 9 and are listed in table 2. Response times of smoke detectors and a tell-tale sprinkler were recorded automatically by activation of a relay which stopped a clock. All tests were recorded with 35 mm still camera or on video tape with separate coverage in the burn room and in the interstitial space. Generally, all instrumentation channels were recorded at 20 second intervals for the smoldering tests and at 13 second intervals for the flaming tests. The data acquisition system was located in an instrumentation trailer adjacent to the main building.

3.1.1 Temperature

Temperatures in the test facility were measured at locations shown in figures 5 thru 9, and outside air temperature was measured. These temperatures were measured by bare beaded chromel-alumel thermocouples made from 0.51 mm (24 gauge) diameter wire.

3.1.2 Smoke Obscuration

The obscuration of smoke was measured at 12 locations as shown in figures 5 thru 9. The smoke meters measured optical density over a 1.0 m (3.28 ft) horizontal path using spotlights as light sources and using photodiodes (PIN 3DP) as receivers.

3.1.3 Carbon Monoxide

Carbon monoxide (CO) was continuously measured at five locations as shown in figures 5 thru 9. In rooms 1, 2, and 3 the CO sample probes were located at approximately head height for a patient laying in bed. In the burn room the CO sample probe was located approximately

0.91 m (3 ft) above the bed. This location was chosen so that it would collect smoke from the fire plume. Another CO probe was located at approximately the mid-height of the interstitial space. CO concentrations were measured with nondispersive, infrared analyzers.

3.1.4 Velocity

Air and gas velocity were measured in the burn room doorway and the window in room 2. In both cases the velocity was measured 0.1 m (4 in) below the top and 0.1 m (4 in) above the bottom of the opening. The room 1 window was open only for tests 1 thru 3 and accordingly the velocity at this window was recorded for these tests only. Velocities were measured with bidirectional probes [2] connected to variable reluctance differential pressure transducers.

3.2 Test Program

The smoke leakage performance of the ceiling system was tested with smoke generated by four types of sources: (1) smoke candle, (2) smoldering fire, (3) low energy flaming fire, and (4) high energy flaming fire. Throughout the tests the doors to rooms 1 and 3 were open and the door to room 2 was closed. The status of doors and windows for all the tests is shown in figure 10. The test schedule for all of the tests except the smoke candle test is listed in table 3.

3.3 Test Procedures

3.3.1 Smoke Candle Test

A commercially available three minute duration smoke candle was set in the center of the flat steel surface of the hospital bed and ignited. Visual observations were made and the test was recorded on video tape. This test was performed so that smoke movement from smoke candles could be compared with smoke movement from real fires.

3.3.2 Smoldering Tests

A smoldering fire of high reproducibility was developed for these tests. The pallet for the smoldering fires was constructed in the following steps:

- a. Fiberglass insulation 0.58 mm (23 in) wide and 89 mm (3.5 in) thick was placed over a plywood board 1.83 m x 0.58 m x 13 mm (72 in x 23 in x 1/2 in) thick.
- b. Three layers of untreated cotton batting 0.69 m (27 in) wide and 25 mm (1 in) thick were placed on top of the fiberglass.
- c. A bedspread of 50 percent polyester and 50 percent cotton was placed on top.
- d. The assembly was then turned over, compressed with approximately 70 N (16 lb) force and the spread was pulled tight and stapled securely on both sides.

The pallet was placed with the plywood side down on the hospital bed in the burn room. Three slits were made in the pallet, approximately 76 mm (3 in) long and 40 mm (1.6 in) deep into the cotton batting. One of these slits was located in the center of the pallet and the other two were located 0.61 m (24 in) from each end and equidistant from the sides. The pallet was ignited by placing a lighted half cigarette in each slit and then pushing the slit shut. The cotton batting had been stored in a room at 30 percent RH and 21° C (70° F).

3.3.3 Low Energy Tests

These tests are referred to as low energy tests because the mattress was filled with fire retardant treated cotton padding. A detailed description of the mattress and bedding for these tests is provided in section 3.4.1. The fire was started in a steel wastebasket

containing 20 sheets of newspaper of which ten crumpled and ten were rolled and placed vertically. The wastebasket was placed in contact with the blanket and top sheet. Each test began when the contents of the wastebasket were ignited with a cigarette lighter. All bedding and wastepaper were kept in a storage room where the humidity was in the range of 30 - 50 percent RH and the temperature was in the range of 16 - 23° C (60 - 74° F).

3.3.4 High Energy Tests

These tests were referred to as high energy tests because the mattress was filled with polyurethane foam. A detailed description of the mattress and bedding for these tests is provided in section 3.4.2. The mattress was one which has been used as part of the NBS mattress flammability test program [3, 4, 5]. A polyethylene wastebasket filled with 443 g (.97 lb) of combustibles was placed next to the bed as was done in the NBS mattress tests. Table 4 lists the contents of the wastebasket. The wastebasket was placed in contact with the bedspread. Each test began when the contents of the wastebasket were ignited with a cigarette lighter. All bedding and wastebasket items were kept in a 50 percent RH conditioning room at a temperature of 21° C (70° F) for at least 24 hours prior to each test in order to be consistent with the prior NBS mattress tests [3].

3.4 Mattresses and Bedding

3.4.1 Low Energy Tests

The mattresses and bedding for the low energy flaming tests were supplied by the Veterans Administration. The mattress was an inner-spring mattress constructed of fire retardant treated cotton felt padding with a retardant treated vinyl impregnated nylon tick covering (outermost layer). The bedding consisted of a blanket, two sheets, a pillow and a pillow case. The pillow had cotton ticking and was filled with duck feathers. A detailed description of the mattress and bedding is provided in table 5. For test 4, the first low energy flaming test,

a fire retardant blanket of a matrix fiber of 50 percent vinyl and 50 percent vinyon was used. In this test only the newspaper in the wastebasket and a small amount of the cotton sheet burned. Because the fire intensity was so low, it was decided to use a cotton blanket furnished by the Veterans Administration for subsequent low energy tests.

3.4.2 High Energy Tests

The mattress and bedding for the high energy tests were the same as the mattress and its bedding materials used in the NBS mattress test program [3]. The mattress chosen was a polyurethane innerspring one which was coded M-02 in the mattress tests. The bedding was obtained from a commercial hospital supplier and was intended for use in health care facilities. The bedding consisted of a cotton drawsheet, two sheets, and a bedspread, a pillow case and pillow filled with shreaded polyurethane foam. A detailed description of the mattress and bedding is listed in table 6.

4. HAZARD ANALYSIS

The primary objective of this project was to study smoke movement through the interstitial space resulting from a fire originating below the space in an occupied room. In addition, a limited discussion regarding the resultant hazard to human life from such fires is also presented. For this paper the hazard analysis was limited to smoke obscuration and CO concentration. It should not be inferred that CO is the only toxic gas that is significant in fire situations. This was the only gas measured due to the limited scope of the project. In this discussion of hazard analysis, temperature was not considered because the primary concern of this study is with the hazards associated with smoke at locations where there is negligible temperature rise due to the fire.

4.1 Smoke Obscuration

The limiting level of smoke obscuration for human safety was selected for two separate hazards in this fire test scenario. The first concerned rescue of a patient from a patient room, and the second involved the use of the corridor as an exit way. Obscuration was measured at a number of locations (section 3.1.2) in order to study smoke movement. For hazard analysis only the smoke meters located 1.5 m (5 ft) above the floor in the patient rooms and in the corridor were considered. Critical levels of obscuration selected for each location were based on investigations by Jin [6, 7]. Jin recommended limits on obscuration based on not reducing the walking speed below that of a blindfolded subject in a smoke free environment. This obscuration was approximately 0.25 OD/m. Accordingly, in this paper, the value of 0.25 OD/m is used as the critical level of smoke obscuration for both the patient rooms and the corridor.

4.2 Carbon Monoxide

CO forms carboxyhemoglobin (COHb) in the blood and thereby reduces the oxygen carrying capacity of the blood. Therefore, percent COHb is a meaningful measure of CO toxicity. The following approximate procedure, adopted for this test program to evaluate COHb, has been employed by O'Neill and Hayes [4, 5].

Steward derived an equation of COHb from experiments with human volunteers [8]. The volunteers were subjected to very high concentrations of CO and their COHb levels were then measured. CO uptake is directly proportional to the breathing rate which is approximately 6.5 l/min for an individual at rest. The breathing rate increases with activity and also from exposure to CO₂. A 4 percent concentration of CO₂ will more than double the breathing rate [9]. Since both of these factors must be considered in a fire situation, a breathing rate of 18 l/min was selected for purposes of analysis. The equation developed based on Steward's work for determining COHb% is:

$$\Delta\text{COHb}\% = 5.98 \times 10^{-4} (\Delta t) [\text{CO}]^{1.036}$$

where Δt is time in minutes and CO is concentration in ppm. An initial value of 0.75 percent COHb was established, based on information provided by Alarie and Zullo [10] for use in the computation. A 25 percent calculated COHb was selected in this study as the critical level of COHb at which incipient incapacitation may occur [11].

In addition to the threshold for time-rated accumulation, another limit must be selected for CO exposure. Instantaneous doses of high levels of CO must also be considered due to the physiological effects such as cardiac arrhythmia [12] which can occur independently of the effects of increased COHb. Claudy [13] reported on the effects of exposure to high concentrations of CO. The results of his work indicate that incipient incapacitation may occur with only a few short breaths at an exposure level of 10,000 ppm CO. And, at a slightly higher concentration of 12,800 ppm Claudy reported that unconsciousness could occur in 2 to 3 breaths, followed by death in 1-3 minutes. Based on this an instantaneous threshold of 10,000 ppm (1.0 percent by Vol) CO was selected as a criterion, in addition to the time integrated exposure resulting in COHb level of 25 percent.

5. TEST RESULTS AND DISCUSSION

5.1 Smoke Candle Test

The smoke candle test was conducted under the following conditions:

1. The burn room door was closed.
2. The window to room 1 was open.
3. The supply and exhaust systems for the four patient rooms were operating.
4. The interstitial space exhaust fans were off.
5. The status of the other doors and the windows was the same as for all of the other tests, as listed in table 3.

As expected, visual observation revealed that the smoke filled the burn room quickly, but there was a much lower level of smoke in the other rooms, the corridor and the interstitial space. Figure 11 indicates that the optical density in the corridor and the interstitial space was considerably lower than the optical density in the burn room. In addition, it was observed that the major path of smoke movement through the suspended ceiling was at joints between the walls and the metal wall molding of the suspension system, in spite of the fact that these joints were filled with open cell foam. In section 5.5, this smoke candle test is compared with the other tests conducted in this series.

5.2 Smoldering Tests

In the first three tests, the burn room door was closed and smoldering fires were set as described in section 3.3.1. The test conditions for these tests are summarized in table 3. Throughout all three tests there was only slight visible smoke in the corridor and rooms 1, 2, and 3. Visual observation after 60 minutes revealed that small quantities of smoke were flowing under the burn room door into the corridor. The CO concentrations outside the burn room were negligible. In all three tests the temperature outside the burn room remained constant, and the temperature 0.1 m (4 in) below the burn room ceiling only increased by 8° C.

5.2.1 Tests 1 and 2

Test 1 was conducted with the supply air and exhaust air on and all the ceiling tiles in place. In order to determine the effect of missing ceiling tiles, test 2 was conducted with two ceiling tiles missing from the burn room ceiling. Figure 12 shows smoke obscuration in the burn room and interstitial space for these two tests. The data from test 1 is for less than 60 minutes because of a failure in the data acquisition software. As expected the obscuration is greater in the interstitial space in test 2 with the ceiling tiles missing from the burn room.

5.2.2 Test 3

In order to determine the effect of the ventilation system on smoke movement, test 3 was a repeat of test 2 except that the supply and exhaust fans to the four patient rooms were shut off. Figure 13 shows the smoke obscuration in the burn room and the interstitial space for tests 2 and 3 showing. There is a substantial increase in smoke concentration when the ventilation system is off.

The window in room 1 was open throughout these tests to determine the effect of an open window on smoke movement. In all three smoldering tests there was flow into room 1 at the bottom of the window and out of room 1 at the top. The air velocities at the window fluctuated in the range of 0 to 0.5 m/s (0 to 0.15 ft/s). This type of flow is indicative of natural air currents which exist in buildings, and would be unusual for a window open to the outside. In such cases the flow is usually dominated by either wind or stack effect or by both. Accordingly, the flow would be in one direction across the opening. Because the burn room door was closed, the open window in room 1 probably had no significant effect on the smoldering fire. However, for tests with the burn room door open, the open window would probably have an affect on the fire. This would impair reproducibility of the tests and yield no benefits. For this reason the window in room 1 was closed for all further tests.

During the smoldering tests the smoke obscuration and CO concentrations did not result in a significant threat to life. CO levels in the burn room were below 0.15 percent for all three tests, and COHb levels for a person in the burn room were well below the critical level. Smoke obscuration was below critical level throughout tests 1 and 2. And, in test 3 smoke obscuration remained below the critical level for the first 30 minutes of the test.

A worry with a smoldering fire is that it will continue until hazardous conditions result, or until the fire develops into a flaming fire. While there was only the slightest visible smoke in the corridor and in rooms 1, 2 and 3, a very irritating smell was present in these spaces after the first few minutes of each test. It is apparent from figures 12 and 13 that smoke obscuration due to the smoldering fires is below the hazard level for at least a half hour. Hospitals have people who are awake 24 hours a day who can smell these fires and then easily extinguish them. Therefore, smoldering fires of the type examined in this test series do not appear to represent a serious problem in hospitals.

5.3 Low Energy Tests

In tests 4 through 10, fire retardant cotton mattress and bedding as described in section 3.4.1 were burned. The test conditions for these tests are summarized in table 3. The burn room door was open for all tests, with the exception of test 7. The window in room 1 was closed for all tests for reasons discussed in section 5.2.2. The status of all windows and doors for these tests is provided in figure 10. Figures 14 and 15 show the upper gas temperatures in the burn room for these tests.

5.3.1 Tests 4 and 5

Test 4 was conducted with both the supply air and the exhaust air on. For this test a fire retardant blanket was used on the bed. This blanket was very successful in limiting the growth of the fire as can be seen from the upper gas temperature in figure 14. Test 5 was the same as test 4 except that a cotton blanket was used to increase the fire intensity. This was successful and cotton blankets were used for the rest of the low energy tests. Figure 16 shows smoke obscuration in the corridor and in the interstitial space for both test 4 and 5. It is apparent that the smoke obscuration is much greater in test 5 when the cotton blanket was on the bed.

During test 5 the burn room and rooms 1 and 3 were open to the corridor. It was visually observed that these spaces filled with smoke after about 2 or 3 minutes. This is also apparent from the smoke obscuration data shown in figure 17. As would be expected the corridor was obscured slightly before rooms 1 and 3. The door to room 2 was closed throughout the test series, and smoke was observed flowing under the door and into room 2. It can be seen from figure 17 that the smoke obscuration in room 2 was considerably lower than that of the corridor or other rooms. Figure 17 shows that the obscuration of the interstitial space during test 5 was much lower than that of the corridor or that of rooms 1 and 3. This indicates that the smoke flow through the open doorway was much greater than that through the ceiling system. During this test there was no indication of smoke movement from the interstitial space to room 2.

Similar observations regarding smoke movement can be obtained by examining CO concentration. Figure 18 shows CO concentrations for test 5. The CO concentrations in the burn room, and rooms 1 and 3 were relatively high, while the concentrations in room 2 and the interstitial space are negligible. It can be observed from figure 18 that the burn room concentration of CO is about twice that measured in rooms 1 and 3. This is because the burn room CO probe samples the gas from the fire plume.

5.3.2 Test 6

The test conditions for test 6 were the same as those for test 5 except that the supply air and the return air were shut off. This test was conducted to determine the extent to which smoke obscuration would increase without ventilation. Figure 19 shows smoke obscurations for test 6. As in test 5 the optical density in the corridor and rooms 1 and 3 increased rapidly while the optical density in the interstitial space and room 2 was much lower. As in test 5 it is apparent that the smoke flow through the open doorway was much greater than the upward smoke flow through the ceiling system. There were no indications of smoke flowing from the interstitial space into room 2.

In comparing smoke obscuration from tests 5 and 6 (figures 17 and 19), it is apparent that the increase in smoke obscuration is dramatic when the ventilation is shut off. This is especially so for room 2 where the optical density was five times greater when the ventilation was off.

5.3.3 Test 7

Test 7 was conducted to determine the effect of a closed burn room door on smoke concentration. This test was the same as test 6 except for the closed door. Figure 20 shows smoke obscurations for test 7. By comparing figures 19 and 20 it is apparent that closing the burn room door significantly reduces the smoke obscuration in the corridor and in rooms 1, 2, and 3. However, these figures also show that closing the burn room door has essentially no effect on smoke obscuration in the interstitial space. This is probably because the major path of smoke movement into the interstitial space is through the burn room ceiling in either case. In addition, there were no indications of smoke flowing from the interstitial space into room 2.

Figure 21 shows CO concentration in the burn room and in room 1 for tests 6 and 7. This data shows that closing the burn room door results in increased CO in the burn room and decreased CO in room 1. The burn room CO concentration is increased to the extent that in test 7 the critical level of COHb is reached in 22.6 minutes. However, in all the other low energy tests where the burn room door was open the critical level was not reached.

5.3.4 Test 8

Test 8 was performed to determine the effect of exhausting two air changes per hour from the interstitial space. With the exception of exhausting the interstitial space, the conditions of this test were the same as those of test 6. It was expected that exhausting the interstitial space would act to pull smoke through the ceiling and into the

interstitial space. Accordingly, the level of smoke in the corridor and patient rooms would decrease. Figure 22 shows smoke obscuration for test 8. In comparing the results of tests 6 and 8 (figures 19 and 22), it is apparent that exhausting the interstitial space did indeed result in reduced smoke obscuration in the corridor and in rooms 1, 2, and 3. Unfortunately, this reduction in obscuration did not result in greatly reduced hazard conditions. It can also be noticed by comparing figures 19 and 22, that exhausting the interstitial space had little effect on the smoke obscuration in the interstitial space. In this test, as in earlier tests, smoke was observed leaking into room 2 through the crack under the door. It should be noted that there were no indications of smoke flowing from the interstitial space into room 2.

5.3.5 Test 9

In order to determine the leakage paths into room 2 and to reconfirm the results of test 8, test 9 was conducted. Test 9 was the same as test 8 except that the cracks around the door to room 2 were sealed with tape. Figure 23 shows smoke obscuration for test 9. In comparing the smoke obscuration for tests 8 and 9 (figures 22 and 23), it is apparent that there was good repeatability between the two tests everywhere except in room 2. As expected, the two figures show that the smoke obscuration in room 2 was lower with the cracks around the door taped. It was observed during test 9 that smoke was flowing into room 2 through the exhaust grill. The exhaust and supply systems were off, and apparently smoke traveled from the burn room to room 2 through the exhaust duct.

As in test 8, the interstitial space exhaust had little effect on the smoke obscuration in the interstitial space, and there was no indication of smoke movement from the interstitial space into room 2.

5.3.6 Test 10

Test 10 was conducted to determine the effect of operating the exhaust system for the patient rooms during a low energy fire. The door to room 2 was still sealed, and during the test no visible smoke was observed in room 2. This can be seen from the smoke obscuration data for test 10 which is provided in figure 24. The reasons for the absence of smoke in room 2 during this test are discussed in detail in section 5.7.

Test 10 is the same as test 6 except that the exhaust air system is on in test 10. Comparison of the smoke obscuration for tests 5 and 10 (figures 19 and 24) shows that the obscuration throughout the facility was considerably lower when the exhaust air was on. This result was anticipated because test 10 is very similar to test 5 (figure 17) where both the exhaust and supply were operating. However, the smoke obscuration from test 10 was lower than that for test 5, indicating that exhaust alone does more to eliminate smoke than exhaust and supply together.

An explanation which might be proposed for this is that the supply system provides combustion air which increases the combustion rate. This explanation does not consider that when the supply fan is off there is an inflow of outside air through whatever small cracks exist in the test facility. This inflow equals the exhaust rate and would also provide combustion air to the fire.

In addition, smoke feedback into the supply air system did not occur because the supply air was completely taken from the outside on the opposite side of the building from where the exhaust air was rejected (figure 4). Another possible effect is that the supply air reduced the ability of the exhaust system to remove smoke from the patient rooms. The supply diffusers were located approximately in the middle of each patient room (figure 3) and the return air grills were located 6 ft

above the floor in each patient room (figures 1 and 4). Because of the proximity of the diffusers and exhaust grill it is likely that the supply air diluted the smoke flowing into the exhaust system. This would reduce the smoke exhaust capability of the exhaust system.

5.4 High Energy Tests

5.4.1 Tests 11 and 12

In tests 11 and 12, polyurethane mattress and bedding as described in section 3.3.4 were burned. The test conditions for these tests are listed in table 3. The burn room door was open for both of these tests. The status of all doors and windows in the test facility is provided in figure 10. Figures 25 and 26 show temperatures for tests 11 and 12. These figures indicate that these tests were highly repeatable.

Test 11 was conducted with all the ventilation fans shut off. For tests 11 and 12, the door to room 2 was sealed to determine the extent of smoke movement through the duct work. Under these circumstances the smoke movement into room 2 would be similar to that into a room which had solid partitions separating it from the fire space. In test 11 as in test 9 smoke was observed flowing into the room 2 through the exhaust duct.

Test 12 was conducted with the air exhausted from the interstitial space at a rate of 2 air changes per hour. The exhaust grill and the supply register in room 2 were sealed off to determine other possible paths of smoke into room 2.

During both tests 11 and 12 visual observation revealed that shortly after ignition there was considerable smoke flow out of the top of the burn room door, and that after about 2 minutes the corridor, and rooms 1 and 3 were obscured with smoke. In addition, during the first 4 minute of tests 11 and 12, smoke was observed flowing into the interstitial space through the cracks between the wall molding and the wall. And, at about 4 minutes the interstitial space filled very rapidly with smoke.

Figure 27 shows smoke obscuration for tests 11 and 12. This confirms the visual observations, described above. Similar trends can be found by observing the CO concentrations shown in figure 28. After about 4 minutes the CO concentration in room 1 increased rapidly, while the CO concentrations in the interstitial space increased at a somewhat lower rate.

It is also apparent from figure 28 that the CO concentrations in room 1 were lower in test 12 when the interstitial space was exhausted. This is similar to the reduced smoke concentrations caused by interstitial exhaust during the low energy fires of tests 8 and 9. It can be observed from both figures 27 and 28 that exhausting the interstitial space has little effect on the smoke concentrations in the interstitial space.

5.4.2 Smoke Leakage into Room 2

The effect of sealing the return grill and the supply diffusers in room 2 should reduce the smoke concentrations in that room by preventing smoke movement through the duct systems. This behavior can be observed by examining smoke obscuration in figure 27 or by examining CO concentration in figure 28. Smoke obscuration and calculated COHb in room 2 were both well below the critical levels selected for this study. The concentration of CO in room 2 was below the instantaneous threshold. However, if the fire had been of longer duration it is possible that the smoke obscuration and COHb might have exceeded critical levels in room 2.

During test 12 smoke may have infiltrated room 2 through the suspended ceiling, through cracks around the door frame, through cracks between the partitions, etc. Upon examination before and after test 12, traces of smoke movement were evident on the ceiling tile around the diffusers in room 2. Visual examination of these smoke traces could not conclusively determine the direction of this smoke movement. It should be pointed out that in a real hospital the interstitial space would be

many times larger, and therefore the smoke in the interstitial space would be more diluted. This indicates that any smoke flow down through a ceiling system would probably result in smoke concentrations even lower than those in room 2 during test 12.

5.4.3 Smoke Movement through the Ceiling

The discussion of tests 11 and 12 in section 5.4.1 included a description of the smoke concentrations in the interstitial space. During the first 4 minutes of these tests, smoke was observed flowing from the burn room into the interstitial space through the cracks between the ceiling wall molding and the wall. Apparently, the open cell foam (section 2) used to seal these cracks was ineffective in stopping smoke movement. At approximately 4 minutes into the test, it was observed that the smoke in the interstitial space increased very rapidly. This rapid increase in smoke concentration in the interstitial space can be observed from the CO concentrations shown in figure 28 and from smoke obscuration in figure 27.

After test 11 the ceiling of the burn room was still intact. However, the metal suspension system was warped which resulted in a large number of cracks which would let smoke flow into the interstitial space. It can be observed from figure 25 that the gas temperature 0.1 m (4 in) below the burn room ceiling was very high; it peaked at 725° C (1340° F) at about 6 minutes into the test. It seems apparent that the high temperature of the combustion gases near the ceiling warped the suspension system and that a greatly increased flow of smoke through the ceiling system resulted. This accounts for the rapid increase in smoke in the interstitial space at about 5 minutes into the test. After test 11 the burn room ceiling was rebuilt for test 12.

Figure 29 shows the pressure difference across the burn room ceiling (see instrument number 56 on figure 8). For this figure a positive pressure indicates that the burn room is at a higher pressure than the interstitial space. It can be observed from figure 29 that in

both tests 11 and 12 the pressure increased to about 9 Pa (0.036 inch H₂O) at about 5 minutes into the test. Then the pressure suddenly dropped to below 1 Pa (0.004 inch H₂O). This drop in pressure coincides with the rapid increase in smoke concentration in the interstitial space. When the suspension system warped, the increased leakage area resulted in both increased gas flow into the interstitial space and decreased pressure differential across the ceiling. It can also be observed from figure 29 that the differential pressures across the ceiling were larger for test 12. This was due to the presence of interstitial exhaust during test 12.

5.5 Comparison of Test Types

5.5.1 Smoke Movement

It is well known that the movement of smoke produced by smoke candles is significantly different than the movement of smoke produced by flaming fires. This is because the smoke from smoke candles lacks the buoyant forces which exist in smoke produced by flaming fires. However, one might think that smoke movement due to smoke candles and smoldering fires would be very similar because in both cases the buoyant forces of the smoke are negligible. A comparison of smoke obscuration for the smoke candle test and test 1 (figure 30) shows that this is not the case. The reason for this is that the rates of smoke production are very different. The smoke candle releases a large quantity of smoke in about three minutes, while the smoldering fire releases smoke slowly for about an hour. Therefore, the smoke movement due to a smoke candle is considerably different from that due to either a flaming test or a smoldering test.

5.5.2 Hazardous Conditions

During the three smoldering tests the CO concentration was considerably below the instantaneous threshold and the calculated COHb was well below the critical level. In the first two smoldering tests (figure 12) smoke obscuration was below the critical level. For test 3

when the ventilation system was off the smoke obscuration (figure 13) was below the critical level throughout the facility except for the burn room. Even in the burn room the hazard level was not reached until 30 minutes into test 3.

In the low and high energy tests smoke obscuration was more severe. With the exception of test 7 all of these tests were conducted with the burn room door open. Test 4 was unique in that a fire retarded blanket was on the bed. With the exception of tests 4 and 7, smoke obscuration for both the low and high energy tests followed the same pattern, i.e. smoke from the burn room flowed into the corridor and then into rooms 1 and 3. Obscuration of these spaces reached the critical level at 1 to 3 minutes into each test.

However, the danger due to CO concentration was very different for the low and high energy tests. The COHb reached the critical level in the burn room for test 7, a low energy test, at 22.6 min. This measurement was not very meaningful for hazard analysis because it was measured 1.53 m (5 ft) above the floor over the bed in the fire plume. The critical level of COHb was not reached for any other low energy tests. However, critical levels of COHb and the instantaneous threshold of CO were reached for several locations in the test facility during the high energy tests. The times required to reach the critical level of COHb and the instantaneous threshold of CO are listed in table 7.

5.5.3 Smoke Detection

Smoke detectors were included in this test series to examine their performance. The ionization detectors used for this test series were the same type as used by Bukowski [14] in a study of detector performance in health care occupancies. Bukowski reported activation times during flaming tests of 15 to 45 s for ionizing detectors in the burn room and 50 to 115 s for ionizing detectors in the corridor.

Throughout this test series smoke detectors were located in the burn room and the corridor as shown in figure 3. Activation times for these detectors are listed in table 8. During the smoldering tests the corridor remained essentially smoke free and accordingly the corridor detector was not activated. It is well known that the activation time of ionization detectors is longer for smoke from smoldering fires than for flaming fires. The activation time during the three smoldering tests was in the range of 27 to 60 minutes which was considerably greater than the activation times during the flaming tests.

As expected, the activation times for the low and high energy flaming tests are for the most part in the same range as those reported by Bukowski. Test 7 is an obvious exception with an activation time of over a half hour for the corridor detector. This was because the burn room door was closed during test 7.

5.6 Interstitial Space Exhaust

The purpose of exhausting the interstitial space in tests 8, 9 and 12 was to prevent smoke in the interstitial space from flowing down into occupied spaces and thereby causing hazardous conditions. This is equivalent to saying that the performance of an interstitial space exhaust system should be such that it subjects the patients to no greater danger than would occur in a hospital in which the interstitial space had a solid floor. Room 2 can be considered a room in which a patient might be subject to smoke flowing through the ceiling from the interstitial space.

Workers who might be in the interstitial space at the time of a fire need to be considered. It is reasonable to expect that maintenance workers are capable of evacuating under their own power. One criteria for allowable levels of smoke obscuration and CO concentration in the interstitial space is that these levels it should be no worse than they would be without an interstitial space exhaust.

Regarding the low energy fires of tests 8 and 9, the following observations have been made in sections 5.3 and 5.5:

- (1) The interstitial space exhaust had little effect on the smoke obscuration in the interstitial space. Calculated COHb in the interstitial space was well below the critical level and the instantaneous threshold of CO was never reached.
- (2) The optical densities in the patient rooms and in the corridor were lower with than without the interstitial space exhaust.
- (3) There was no indication of smoke movement from the interstitial space into room 2.

Therefore the interstitial space exhaust system successfully met the above requirements when it was exposed to a low energy fire in these tests.

Regarding the high energy fire of test 12, the following observations were made in sections 5.4 and 5.5:

- (1) The interstitial space exhaust had little effect on the smoke obscuration in the interstitial space. The time for calculated COHb to reach the critical level was essentially the same with or without the exhaust.
- (2) The optical densities in the corridor and in the patient rooms were lower with than without the interstitial space exhaust.
- (3) There was some slight smoke movement through the ceiling of room 2. However, the smoke obscuration was below the critical level as was the calculated COHb. The CO concentrations never reached the instantaneous threshold in room 2.

It can not be said that the exhaust system totally satisfied the above requirements because there was some smoke movement through the ceiling during the high energy fires. However, it can be said that this smoke movement did not result in hazardous conditions in room 2. So, it would appear that the interstitial exhaust system performed reasonably well during the high energy fire. In a real hospital where the interstitial space is larger, the result would be to dilute the smoke in the interstitial space and thus reduce the problem even further.

5.7 Patient Room Exhaust

During test 10 the patient room exhaust system was operating. As discussed in section 5.3.6, this exhaust reduced smoke concentration in the corridor and rooms 1 and 3. The door to room 2 was sealed and room 2 remained essentially smoke free throughout the test. This might lead someone to believe that the patient room exhaust could be used to prevent smoke movement through the interstitial space. However, such a conclusion is unjustified for reasons described below.

The pressure difference across the burn room ceiling for test 10 is shown in figure 29. The pressure in the first 5 minutes of the test indicates that the burn room was at a higher pressure than the interstitial space. This would result in smoke flowing from the burn room into the interstitial space. This positive pressure was due to the buoyancy of the gas in the burn room as can be seen from the temperature curve for this test in figure 15. After about 5 minutes the temperature in the burn room decreased. With the buoyancy forces thus decreased, the exhaust system dominated air flow across the ceiling. The negative pressure across the ceiling after 5 minutes (figure 29) indicates flow from the interstitial space into the burn room. Therefore, except for the first 5 minutes of this test, no smoke flowed into the interstitial space. Without similar pressures in room 2, air must have been pulled by the exhaust fan from the interstitial space into room 2. The fact that there was so little smoke in the interstitial space explains why room 2 remained essentially smoke free during test 10.

Unfortunately the exhaust system could not be tested during a high energy fire due to temperature limitations of the fan. This would not necessarily be the case for real buildings where exhaust fans serving larger areas would be subjected to lower temperatures due to dilution. However, observation of the results of the high energy tests can yield insight into what would happen if a high energy fire was exhausted. It was seen in the first few minutes of test 10 that temperatures of 100° C in the burn room forced smoke into the interstitial space in spite of the inhibiting effect of the patient room exhaust system. The higher temperatures from the high energy tests (figures 25 and 26) would result in much more smoke being forced into the interstitial space over a longer period of time. In such a situation, the exhaust system would pull this same smoke from the interstitial space into room 2. Therefore, it can be concluded that if the conditions of test 10 were repeated for a high energy fire, significant levels of smoke would have accumulated in room 2. These resulting room 2 concentrations would be even higher in the case of a longer duration fire, which is frequently the case in real buildings.

5.8 Smoke Movement Paths

During this test series there was smoke movement through (1) open doorways, (2) the crack under the doors, (3) the exhaust duct system, and (4) the cracks in the ceiling system. During all high energy tests and low energy tests except for test 7, there was considerable smoke movement through the open burn room door into the corridor and from the corridor into rooms 1 and 3 through open doors. During these tests the smoke obscuration in the corridor and in rooms 1 and 3 were all in the same range and were considerably higher than the smoke obscuration in the interstitial space or in room 2. As one might expect, this indicates that the smoke movement through the open doors is greater than that through other paths mentioned above.

During the smoldering tests, small quantities of smoke were observed leaking through the crack under the closed burn room door and into the corridor. However, the resulting smoke obscuration in the corridor was negligible. During tests 5, 6, and 8 smoke was observed flowing from the corridor into room 2 through the crack under the door to room 2. Although, this was the only observed path of smoke movement into room 2 during these tests, and the resulting smoke obscurations in room 2 were significant. For test 9 the cracks around the door to room 2 were sealed, and smoke was observed flowing into room 2 through the exhaust duct (exhaust system not operating). The resulting smoke obscuration in room 2 was considerably lower during this test than when the door was not sealed. The leakage through the exhaust duct system was less than that through the crack under the door to room 2. A similar leakage was observed through the exhaust duct system during high energy fire of test 11.

For test 12, the supply register and the exhaust grill were sealed in room 2. Smoke traces were observed around the ceiling tile near the supply register after test 12. These traces indicated that there was some smoke movement through the ceiling system, however it could not be determined whether this smoke movement was into or out of room 2. The smoke obscuration in room 2 during test 12 was quite low. This indicates that any leakage that might have occurred from the interstitial space into room 2 through the ceiling system would have been much less than that through the other smoke movement paths discussed.

6. SUMMARY AND CONCLUSIONS

1. The use of the interstitial space exhaust at a rate of two air changes per hour as described in this test series will effectively prevent hazard conditions due to smoke downflow through the suspended ceiling from the interstitial space during low or high energy fires represented in this test series. This is discussed in detail in section 5.6.

2. There was an indication of smoke leakage through the ceiling of room 2 during test 12, a high energy test. While the direction of the leakage was not determined, it is possible that smoke was leaking into room 2 from the interstitial space. Hazard conditions in room 2 due to smoke obscuration or due to CO concentrations did not result. It can be further stated that this leakage was considerably less than leakages observed through open doorways, through cracks under closed doors, and through the exhaust duct system. This is discussed in section 5.8.
3. Smoldering fires of the type examined in this test series are not a significant problem in hospitals. This is discussed in section 5.2.
4. When the ceiling system was not subjected to high temperatures, the most significant smoke leakage into the interstitial space was observed flowing through the crack between the wall and the wall molding of the ceiling suspension system. This was observed in the smoke candle test and during the first 4 minutes of tests 11 and 12. This leakage existed in spite of the fact that this crack was filled with an open cell foam.
5. When the ceiling system was exposed to high temperatures the metal grid system warped and greatly increased the smoke flow through the ceiling. This is discussed in detail in section 5.4.3.
6. The use of the fire retardant blanket (matrix fiber of 50 percent vinyl and 50 percent vinyon) on the bed fire of test 4 resulted in significantly lower temperature and smoke production than the use of a cotton blanket on the bed fire. This is discussed in section 5.3.1.

7. The use of the patient room exhaust air system reduced smoke concentration throughout the test facility in test 10 as discussed in section 5.3.6. During this low energy fire room 2 was virtually smoke free. However, in the event of a high energy fire significant smoke levels in room 2 would probably result even with this exhaust system. The reasons for this statement are discussed in section 5.7.
8. Closing the burn room door for the low energy fire of test 7 resulted in higher CO concentrations in the burn room. Test 7 was the only low energy test where critical levels of calculated COHb were reached in the burn room. However, closing the burn room door did result in lower smoke obscuration and CO concentrations outside the burner room. This is discussed in section 5.3.6.
9. The movement of smoke produced by a smoke candle is considerably different than the movement of smoke from a flaming or smoldering fire. This is discussed in section 5.5.1.
10. The activation times of the ionizing smoke detectors during flaming tests were found to be consistent with previous work. This is discussed in section 5.5.3.

7. ACKNOWLEDGEMENTS

Appreciation is expressed to Lionel Issen and William Bailey for their contributions to the design and construction of the test facility. Appreciation is also expressed to Warren Hayes, Richard Zile and Melvin Womble for instrumentating of the test facility and conducting the experiments. The author is especially appreciative of Warren Hayes for his effort in developing a highly reproducible smoldering fire. Thanks are due to Richard Peacock who wrote the computer graphics

routine used to generate the graphs in this paper. Thanks are also due to Sandra Nowstrup for using that routine to generate those graphs. Special thanks are due to Emil Braun who wrote the computer routines used for data acquisition and data reduction.

8. REFERENCES

- [1] Fire Resistance Directory, Underwriters Laboratory (Jan. 1980).
- [2] McCaffrey, B. J. and Heskestad, G., A Robust Bidirectional Low Velocity Probe for Flame and Fire Application, Combustion and Flame, Vol. 26, 125-7, (1976).
- [3] Babrauskas, V., Combustion of Mattresses Exposed to Flaming Ignition Sources, Part 1 Full-Scale Tests and Hazard Analysis, Nat. Bur. Stand. (U.S.), NBSIR 77-1290, (Sept. 1977).
- [4] O'Neill, J. G. and Hayes, W. D., Full-Scale Fire Tests with Automatic Sprinklers in a Patient Room, Nat. Bur. Stand. (U.S.), NBSIR 79-1749, (June 1979).
- [5] O'Neill, J. G. and Hayes, W. D., Full-Scale Fire Tests with Automatic Sprinklers in a Patient Room - Part II, Nat. Bur. Stand. (U.S.), NBSIR 80-2097, (July 1980).
- [6] Jin, T., Visibility through Fire Smoke, Part 2, Report of the Fire Research Institute of Japan, No. 33, 31-48 (1971). Part 5, Report of Fire Research Institute of Japan, No. 42, 12-18 (1975).
- [7] Jin, T., Visibility through Fire Smoke, Main Reports on Production, Movement and Control of Smoke in Buildings, pp. 100-153, Japanese Association of Fire Science and Engineering (1974).

- [8] Steward, R. D., et al, Experimental Human Exposure to High Concentrations of Carbon Monoxide, Architectural Environmental Health, Vol. 26, 1-7 (Jan. 1973).

- [9] Parker, J. E., Jr. and West, V. R., Bioastronautics Data Book, NASA SP-3006, Chapter II, Scientific and Technical Information Office, NASA (1973).

- [10] Alarie, Y. and Zullo, P., Predicting Carboxyhemoglobin for Different Patterns of Carbon Monoxide Exposure, Industrial Health Foundation Symposium on Carbon Monoxide, pp 18-46, Pittsburgh, Pa (1974).

- [11] Kimmerle, G., Aspects and Methodology for the Evaluation of Toxicological Parameters during Fire Exposure, Journal of Fire and Flammability/Combustion Toxicology, Vol. 1, 4-41 (Feb. 1974).

- [12] Stewart, R. D., The Effect of Carbon Monoxide on Man, Journal of Fire and Flammability/Combustion Toxicology, Vol. 1, 167-176 (1974).

- [13] Claudy, W. D., Respiratory Hazards of the Fire Service, National Fire Protection Assn., Boston, MA (1957).

- [14] Bukowski, R. W., Tests on the Performance of Automatic Fire Detectors in Health Care Occupancies - A Preliminary Report, Nat. Bur. Stand. (U.S.), NBSIR 79-1739 (April 1979).

EXISTING BUILDING




Figure 1. Floor plan of test facility






Figure 2. Section of test facility



SYMBOLS


- Ⓢ TELL TAIL SPRINKLER
- Ⓛ SMOKE DETECTOR
- ⓈⓁ SUPPLY AIR DIFFUSER

Figure 3. Ceiling plan of test facility



NOTE: Fans 3, 4, 5 and 6 serve the interstitial space.

Figure 4. Ventilation system for test facility




SYMBOLS

- THERMOCOUPLE
- ⊖ CO PROBE
- ➡ SMOKE METER LIGHT PATH
- ▽ VELOCITY PROBE
- PRESSURE PROBE
- Ⓢ SMOKE DETECTOR
- Ⓣ TELL TAIL SPRINKLER

*Instruments used for tests 1-3 only.
 **Instruments used for tests 4-6 and 8-10.

Figure 5. Instrumentation plan for test facility




SYMBOLS

● THERMOCOUPLE

⊖ CO PROBE

➡ SMOKE METER PATH


Figure 6. Instrumentation plan for interstitial space



SYMBOLS

- THERMOCOUPLE
- ← SMOKE METER LIGHT PATH
- ▽ VELOCITY PROBE
- ▲▲ INSTRUMENTS USED FOR TESTS 4 – 6 AND 8 – 10


Figure 7. Instrumentation in burn room doorway



SYMBOLS

- THERMOCOUPLE
- ⊖ CO PROBE
- ← SMOKE METER PATH
- PRESSURE PROBE
- Ⓢ SMOKE DETECTOR
- Ⓢ TELL TAIL SPRINKLER
- ▲ INSTRUMENTS USED FOR TESTS 1-3 ONLY

Figure 8. Instrumentation in burn room



SYMBOLS

- THERMOCOUPLE
- ⊖ CO PROBE
- ← SMOKE METER LIGHT PATH
- ▽ VELOCITY PROBE
- ▲ INSTRUMENTS USED FOR TESTS 1-3 ONLY

NOTES:

1. Room 2 window was open for tests 1-3 only. All other windows were closed throughout the test series.
2. Heights of smoke meter, thermocouple and CO probe in rooms 2 and 3 are the same as for room 1.

Figure 9. Instrumentation in room 1




Figure 10. Floor plan for test facility showing status of doors and windows during the tests




Figure 11. Smoke obscuration for the smoke candle test.




Figure 12. Smoke obscuration in the burn room and the interstitial space for tests 1 and 2.




Figure 13. Smoke obscuration in the burn room and the interstitial space for tests 2 and 3.




Figure 14. Upper gas temperatures for tests 4 through 7.




Figure 15. Upper gas temperatures for tests 8 through 10.




Figure 16. Smoke obscuration for tests 4 and 5.




Figure 17. Smoke obscuration for test 5.




Figure 18. Carbon monoxide concentrations for test 5.




Figure 19. Smoke obscuration for test 6.




Figure 20. Smoke obscuration for test 7.




Figure 21. Carbon monoxide concentrations for tests 6 and 7.




Figure 22. Smoke obscuration for test 8.




Figure 21. Carbon monoxide concentrations for tests 6 and 7.




Figure 22. Smoke obscuration for test 8.




Figure 23. Smoke obscuration for test 9.




Figure 24. Smoke obscuration for test 10.




Figure 23. Smoke obscuration for test 9.




Figure 24. Smoke obscuration for test 10.




Figure 23. Smoke obscuration for test 9.




Figure 24. Smoke obscuration for test 10.




Figure 25. Temperatures for test 11.




Figure 26. Temperatures for test 12.




Figure 27. Smoke obscuration for tests 11 and 12.




Figure 28. Carbon monoxide concentrations for tests 11 and 12.




Figure 29. Pressure difference across burn room ceiling for tests 10, 11 and 12.




Figure 30. Smoke obscuration for the smoke candle test and test 1.

Table 1. Fan Schedule

Fan Number	Capacity (cfm)	Type	Use
1	500	Centrifugal	Supply
2	500	Centrifugal	Exhaust
3	300	Radial	Ventilation of inter- stitial space
4	120	Radial	
5	120	Radial	
6	300	Radial	

Table 2. List of Instrumentation

Number	Thermocouples
00	Burn room 0.1 m (4 in) below ceiling
01	Burn room 0.2 m (8 in) below ceiling
02	Burn room 0.3 m (12 in) below ceiling
03	Burn room 0.4 m (16 in) below ceiling
04	Burn room 0.8 m (31 in) below ceiling
05	Burn room 1.2 m (3.9 ft) below ceiling
06	Burn room floor
07	Burn room doorway 0.1 m (4 in) below top
08	Burn room doorway 0.1 m (4 in) above floor
09	Burn room floor under bed
10	Burn room floor under wastebasket
11	Burn room 0.13 m (5 in) below ceiling ⁽¹⁾
12	Burn room 1.53 m (5.0 ft) above floor ⁽¹⁾
13	Burn room 0.81 m (32 in) above floor ⁽¹⁾
14	Room 1 - 1.53 m (5.0 ft) above floor
15	Room 2 - 1.53 m (5.0 ft) above floor
16	Room 3 - 1.53 m (5.0 ft) above floor
17	Corridor 1.53 m (5.0 ft) above floor
18	Corridor 0.13 m (5 in) below ceiling
19	Interstitial space 0.76 m (30 in) below top
20	Interstitial space 0.13 m (5 in) below top ⁽¹⁾
23	Window of room 1 - 0.1 m (4 in) below top ⁽¹⁾
24	Window of room 2 - 0.1 m (4 in) above bottom ⁽¹⁾
25	Outside air
11A	Burn room doorway 0.1 m (4 in) below top ⁽²⁾
12A	Burn room doorway 1.53 m (5.0 ft) above floor ⁽²⁾
Number	Smoke Meters
30	Burn room 0.13 m (5 in) below ceiling ⁽¹⁾
31	Burn room 1.53 m (5.0 ft) above floor ⁽¹⁾
32	Burn room 0.81 m (32 in) above floor ⁽¹⁾
33	Room 1 - 1.53 m (5.0 ft) above floor
34	Room 2 - 1.53 m (5.0 ft) above floor
35	Room 3 - 1.53 m (5.0 ft) above floor
36	Corridor 1.53 m (5.0 ft) above floor
37	Corridor 0.13 m (5 in) below ceiling
38	Interstitial space 0.76 m (30 in) below top
39	Interstitial space 0.13 m (5 in) below top ⁽²⁾
30A	Burn room doorway 0.1 m (4 in) below top ⁽²⁾
31A	Burn room doorway 1.53 m (5.0 ft) above floor ⁽²⁾

¹These instruments were only used for tests 1-3.

²These instruments were used for tests 4-6 and 8-10.

Table 2. List of Instrumentation (cont'd)

Number	CO Probes
40	Burn room 1.53 m (5.0 ft) above floor ⁽³⁾
41	Room 1 - 0.81 m (32 in) above floor
42	Room 2 - 0.81 m (32 in) above floor
43	Room 3 - 0.81 m (32 in) above floor
44	Interstitial space 0.76 m (30 in) below top ⁽³⁾
Number	Velocity Probes
50	Burn room doorway 0.1 m (4 in) below top
51	Burn room doorway 0.1 m (4 in) above bottom
54	Window of room 1 - 0.1 m (4 in) below top ⁽¹⁾
55	Window of room 1 - 0.1 m (4 in) above bottom ⁽¹⁾
Number	Differential Pressure
56	Across burn room ceiling

¹These instruments were only used for tests 1-3.

³These instruments malfunctioned during test 8.

Table 3. Test Schedule

Test ¹	Test Type	Burn Room Door	Room 1 Window	Supply Air System	Exhaust Air System	Interstitial Space Exhaust	Remarks
1	Smoldering	Closed	Open	On	On	Off	
2	Smoldering	Closed	Open	On	On	Off	2 ceiling tiles removed from burn room ceiling
3	Smoldering	Closed	Open	Off	Off	Off	2 ceiling tiles removed from burn room ceiling
4	Low Energy	Open	Closed	On	On	Off	Flame retardant blanket on cotton mattress
5	Low Energy	Open	Closed	On	On	Off	Tests 5 through 10 had cotton blanket on cotton mattress
6	Low Energy	Open	Closed	Off	Off	Off	
7	Low Energy	Closed	Closed	Off	Off	Off	
8	Low Energy	Open	Closed	Off	Off	On ²	
9	Low Energy	Open	Closed	Off	Off	On ²	Cracks around room 2 door tapped for rest of tests
10	Low Energy	Open	Closed	Off	On	Off	
11	High Energy	Open	Closed	Off	Off	Off	Polyurethane mattress
12	High Energy	Open	Closed	Off	Off	On ²	Polyurethane mattress - return and supply grills sealed in room 2

¹In all test room 1 and 3 doors were open; room 2 door was closed; and the exterior doors from the corridor and from the burn room were closed.

²Interstitial space exhaust rate was 52 l/s (110 cfm).

Table 4. Ignition Source

Wastebasket -- Polyethylene wastebasket

Size: 248 mm x 178 mm x 254 mm high
Weight: 282 g (.6 lb)

Trash contents, in order of stacking

- 1 -- Polyethylene liner
- 16 -- Sheets of newspaper
- 1 -- Paper cup, 85 g (3 oz.), crumpled
- 2 -- Sheets of writing paper
- 3 -- Tissues, paper handkerchief, crumpled
- 1 -- Cigarette pack, crumpled
- 1 -- Milk carton, 227 g (8 oz.)
- 2 -- Paper cup, 85 g (3 oz.), crumpled
- 1 -- Cigarette pack, crumpled
- 1 -- Sheet of writing paper, crumpled
- 2 -- Tissues, paper handkerchief, crumpled

Total weight of contents: 443 g (.97 lb)

Combined weight, wastebasket and contents: 725 g (1.6 lb)

Table 5. Technical Data for Mattress and
Bedding for Tests 4 - 10

Mattress	Size (m)		Thickness	Total Weight (kg)
	Width	Length		
Fire Retardant Cotton Innerspring	0.91	2.03	0.17	23

Bedding Item	Size (m)		Composition	Total Weight (kg)
	Width	Length		
Fire Retardant Blanket ⁽¹⁾	2.29	1.68	Matrix Fiber 50% vinyl 50% vinyon	1.41
Cotton Blanket ⁽²⁾	2.29	1.68	Cotton	1.54
Sheet	2.74	1.96	65% Polyester 35% Cotton	0.65
Pillow Case	0.91	0.53	65% Polyester 35% Cotton	0.13
Pillow	0.69	0.52	Cotton Cover, Duck Feather Filling	1.50

¹Fire retardant blanket used in test 4 only.

²Cotton blanket used in tests 5-10.

Table 6. Technical Data for Mattress and Bedding
for Tests 11 and 12

Mattress	Width	Size (m) Length	Thickness	Total Weight (kg)	Weight Combustibles (kg)
Polyurethane Innerspring	0.89	2.03	0.17	15	6

Bedding Item	Size (m) Width	Length	Composition	Total Weight (kg)
Spread	2.79	1.93	50% Cotton 50% Polyester	1.07
Sheet and Drawsheet	2.64	1.83	50% Cotton 50% Polyester	0.60
Pillow Case	0.91	0.53	50% Cotton 50% Polyester	0.60
Pillow - Filling			Polyurethane	0.67
- Cover	0.69	0.52	Cotton	0.16
Pillow Protector	0.69	0.53	Polyvinyl chloride	0.90

Table 7. Times to Hazard Level Due to CO Concentrations

Test	Space	Time (min)	
		COHb >25%	CO >1%
7	Burn Room	22.6	-
11	Burn Room	-	4.7
11	Room 1	9.2	-
11	Room 3	9.5	-
11	Interstitial Space	19	-
12	Burn Room ⁽¹⁾	-	-
12	Room 1	9.8	-
12	Room 3	11.1	-
12	Interstitial Space	18	-

¹CO analyzer failure.

Table 8. Smoke Detector Activation Times

Test	Test Type	Time (sec)	
		Burn Room	Corridor
1	Smoldering	3567	N/A
2	Smoldering	2679	N/A
3	Smoldering	1604	N/A
4	Low Energy	43.7	71.2
5	Low Energy	37.2	49.4
6	Low Energy	15.2	26.7
7	Low Energy	20.0	2024
8	Low Energy	34.9	53.1
9	Low Energy	54.5	72.3
10	Low Energy	54.4	66.6
11	High Energy	20.4	37.4
12	High Energy	22.0	42.6

Note: N/A = not activated during test

U.S. DEPT. OF COMM. BIBLIOGRAPHIC DATA SHEET (See instructions)	1. PUBLICATION OR REPORT NO. NBSIR 81-2444	2. Performing Organ. Report No.	3. Publication Date February 1982
4. TITLE AND SUBTITLE SMOKE MOVEMENT THROUGH A SUSPENDED CEILING SYSTEM			
5. AUTHOR(S) John H. Klote			
6. PERFORMING ORGANIZATION (If joint or other than NBS, see instructions) NATIONAL BUREAU OF STANDARDS DEPARTMENT OF COMMERCE WASHINGTON, D.C. 20234			7. Contract/Grant No. 8. Type of Report & Period Covered Final Report
9. SPONSORING ORGANIZATION NAME AND COMPLETE ADDRESS (Street, City, State, ZIP) Veterans Administration Department of Health and Human Services Office of Construction Research and Washington, D.C. 20201 Washington, D.C. 20420			
10. SUPPLEMENTARY NOTES <input type="checkbox"/> Document describes a computer program; SF-185, FIPS Software Summary, is attached.			
11. ABSTRACT (A 200-word or less factual summary of most significant information. If document includes a significant bibliography or literature survey, mention it here) A series of full-scale tests were conducted to evaluate smoke movement through a suspended ceiling and into an interstitial space of a hospital type facility. A test facility specifically constructed for this project is described. The test series consisted of one smoke candle test and 12 fire tests including both smoldering and flaming fires. Smoke movement through the suspended ceiling system was evaluated in terms of the total smoke movement through the test facility. The effects of ventilation and smoke exhaust on smoke concentration in the test facility were investigated.			
12. KEY WORDS (Six to twelve entries; alphabetical order; capitalize only proper names; and separate key words by semicolons) Ceiling systems; hazard analysis; hospitals; interstitial space; mattresses; smoke control; smoke exhaust; smoke movement; ventilation systems			
13. AVAILABILITY <input checked="" type="checkbox"/> Unlimited <input type="checkbox"/> For Official Distribution. Do Not Release to NTIS <input type="checkbox"/> Order From Superintendent of Documents, U.S. Government Printing Office, Washington, D.C. 20402. <input checked="" type="checkbox"/> Order From National Technical Information Service (NTIS), Springfield, VA. 22161			14. NO. OF PRINTED PAGES 77 15. Price \$10.50

